

Underground Storage Tanks (USTs) Public Record

General Information

Public Record Posted Date: 10/30/24Total Number Of Active UST Facilities: 7468Total Number Of Active USTs: 2940

Summary Information For On-Site Inspections

Number Of UST Facilities Inspected: 1350Inspection Period Dates: 10/1/23 To: 9/30/24Percent Compliance (Technical Compliance Rate Measure): 45.33%

Note: Compliance rate is based on the combined performance measures indicated for technical compliance rate with state and Federal UST requirements.

Summary Information For Release

Number Of Confirmed UST Releases: 20Release Reporting Period Dates: 10/1/23 to 9/30/24

Summary Information For Release Sources And Causes

Source			Cause													
			Spill		Overfill		Phys/Mech Damage		Corrosion		Install Problem		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	2	10													2	100
Piping	7	35					3	42.9							4	57.1
Dispenser																
STP	1	5													1	100
Delivery Problem																
Other	2	10					1	50							1	50
Unknown (Optional)	8	40													8	100
Totals	20						4	20							16	80

"Unknown" is based on an unidentifiable source or cause of release.

"Other" is an identifiable source or cause of release that does not fit specific locations identified in the chart.